



Control Number: 51415



Item Number: 577

Addendum StartPage: 0

RECEIVED

SOAH DOCKET NO. 473-21-0538 2021 MAY 20 PM 4:31  
PUC DOCKET NO. 51415

FILED  
FILING CLERK

**SOUTHWESTERN ELECTRIC POWER COMPANY'S RESPONSE TO CITIES  
ADVOCATING REASONABLE DEREGULATION'S NINTH SET OF REQUESTS FOR  
INFORMATION**

**Question No. CARD 9-20:**

Provide SWEPCO's annual system SAIDI and SAIFI due to transmission line outages, including major storm events, for each of the last ten calendar years.

**Response No. CARD 9-20:**

See CARD 9-20 Attachment 1 for SWEPCO's annual system SAIDI and SAIFI due to transmission line outages, including major storm events, for each of the last ten calendar years.

Prepared By: William M. Romine

Title: Regulatory Consultant Staff

Sponsored By: Daniel R. Boezio

Title: VP Trans Field Services

Month End Date	SAIDI	SAIFI
12/31/2011	50.43	0.397
12/31/2012	43.00	0.377
12/31/2013	39.68	0.304
12/31/2014	51.79	0.346
12/31/2015	78.90	0.362
12/31/2016	35.54	0.301
12/31/2017	75.62	0.360
12/31/2018	45.68	0.338
12/31/2019	76.16	0.463
12/31/2020	105.83	0.498

Include Major Event Days

Exclude Interrupt Type Momentary;  
Include Current Record Status Approved  
Include Major Cause Code Distribution  
Station, Transmission Line, Transmission  
Station